



ASHRAE 90.1 Certification Bulletin

Date June 3, 2011

Subject: Allied Magic Pak Products – ASHRAE 90.1

ASHRAE 90.1 – Energy Standard for Buildings outlines the minimum efficiency requirements for equipment including most types of HVAC equipment. Table 6.8.1 outlines these prescriptive requirements. Allied Air Magic Pak products are tested to AHRI Standard 390 – Single Package Vertical Equipment and the minimum efficiency requirements for this product category are listed in ASHRAE 90.1 Table 6.8.1D. All Allied Magic Pak products meet or exceed the current minimum requirement of 9.00 EER.

**Dave Winningham
Team Leader – Cooling Products**